

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2018010301115791

Valid from: Dec.08,2025

Valid until: Aug.09,2031

NAME AND REGISTERED ADDRESS OF THE APPLICANT Jiangsu Zhibo Electric Co., Ltd.
No. 28, Kechuang Road, Sucheng Economic Development Zone, Suqian City

NAME AND REGISTERED ADDRESS OF THE MANUFACTURER Jiangsu Zhibo Electric Co., Ltd.
No. 28, Kechuang Road, Sucheng Economic Development Zone, Suqian City

NAME AND LOCATION OF THE FACTORY Jiangsu Zhibo Electric Co., Ltd.
No. 6, Mochou Lake Road, Susu Industrial Park, Suqian City

PRODUCT NAME, MODEL AND SPECIFICATION Low-voltage reactive power compensation assemblies
SVC 主母线:InA=601A ~ 87A,Icw=15kA;Ue=400V,Ui=690V; 430kvar ~ 60kvar;混合补偿(单相、三相结合补偿);50Hz;IP41、IP40、IP31、IP30,户内型;控制投切电容器的元件类型:复合开关

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS GB/T 15576-2020

TYPE OF CERTIFICATION SCHEMES Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

Date of original issued: May.24,2020

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

郑士泉

SIGNATURE

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.
Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86 10 83886666
<http://www.cqc.com.cn>